

Screened LSZH Type 1

- DECLARATION OF PERFORMANCE - No. CPR002/LSZH5**
- Unique identification code of the product-type:
BS 4737 Type 1 Screened Low Smoke Zero Halogen
 - Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):
VSZ-S4WT, VSZ-S4BR, VSZ-S6WT, VSZ-S6BR, VSZ-S8WT, VSZ-S8BR
 - Intended use or uses of the construction product, in accordance with the applicable harmonized technical specifications, as foreseen by the manufacturer:
Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
 - Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
**Ventcroft Ltd.
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire.
WA7 1QG, United Kingdom.
Tel.: +44 1928 581098, Fax.: +44 1928 581099, Email.: sales@ventcroft.co.uk**



Ventcroft Limited
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire
WA7 1QG, UK
Telephone: 01928 581098
Fax: 01928 581099
E-Mail: info@ventcroft.co.uk
Web: www.ventcroft.co.uk



Fire Performance Cable

- Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
N/A
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 3
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
The determination of the product type on the basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product, carried out by the notified testing laboratory No. 2661 (BASEC)

| Essential characteristics | Performance | Harmonized technical specification |
|---------------------------|----------------|------------------------------------|
| Reaction to fire | D ₀ | EN 50575:2014 |
| Dangerous substances | None | |

- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.
- This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:

Ian Rotherham (Name) Technical Director (function)
Runcorn, United Kingdom 28th June 2019 (place and date of issue) (Signature)



Registered Office: Faraday Road, Astmoor Industrial Estate, Runcorn, Cheshire, WA7 1QG
Registered in England, Reg No. 2038810



Fire Cable Clips



Intruder Alarm Cable

Unscreened LSZH Type 1

- DECLARATION OF PERFORMANCE - No. CPR002/LSZH5**
- Unique identification code of the product-type:
BS 4737 Type 1 Unscreened Low Smoke Zero Halogen
 - Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):
VSZ-4WT, VSZ-4BR, VSZ-6WT, VSZ-6BR, VSZ-8WT, VSZ-8BR
 - Intended use or uses of the construction product, in accordance with the applicable harmonized technical specifications, as foreseen by the manufacturer:
Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
 - Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
**Ventcroft Ltd.
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire.
WA7 1QG, United Kingdom.
Tel.: +44 1928 581098, Fax.: +44 1928 581099, Email.: sales@ventcroft.co.uk**



Ventcroft Limited
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire
WA7 1QG, UK
Telephone: 01928 581098
Fax: 01928 581099
E-Mail: info@ventcroft.co.uk
Web: www.ventcroft.co.uk



Fire Performance Cable

- Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
N/A
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 3
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
The determination of the product type on the basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product, carried out by the notified testing laboratory No. 2661 (BASEC)

| Essential characteristics | Performance | Harmonized technical specification |
|---------------------------|----------------|------------------------------------|
| Reaction to fire | D ₀ | EN 50575:2014 |
| Dangerous substances | None | |

- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.
- This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:

Ian Rotherham (Name) Technical Director (function)
Runcorn, United Kingdom 28th June 2019 (place and date of issue) (Signature)



Registered Office: Faraday Road, Astmoor Industrial Estate, Runcorn, Cheshire, WA7 1QG
Registered in England, Reg No. 2038810



Fire Cable Clips



Intruder Alarm Cable

Screened LSZH 12 Core Type 1

- DECLARATION OF PERFORMANCE - No. CPR001/LSZH5**
- Unique identification code of the product-type:
BS 4737 Type 1 Screened Low Smoke Zero Halogen
 - Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):
VSZ-S12W
 - Intended use or uses of the construction product, in accordance with the applicable harmonized technical specifications, as foreseen by the manufacturer:
Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
 - Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
**Ventcroft Ltd.
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire.
WA7 1QG, United Kingdom.
Tel.: +44 1928 581098, Fax.: +44 1928 581099, Email.: sales@ventcroft.co.uk**



Ventcroft Limited
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire
WA7 1QG, UK
Telephone: 01928 581098
Fax: 01928 581099
E-Mail: info@ventcroft.co.uk
Web: www.ventcroft.co.uk



Fire Performance Cable

- Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
N/A
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 3
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
The determination of the product type on the basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product, carried out by the notified testing laboratory No. 2661 (BASEC)

| Essential characteristics | Performance | Harmonized technical specification |
|---------------------------|------------------|------------------------------------|
| Reaction to fire | E ₁₂₀ | EN50575:2014 |
| Dangerous substances | None | |

- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.
- This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:

Ian Rotherham (Name) Technical Director (function)
Runcorn, United Kingdom 1st July 2017 (place and date of issue) (Signature)



Registered Office: Faraday Road, Astmoor Industrial Estate, Runcorn, Cheshire, WA7 1QG
Registered in England, Reg No. 2038810



Fire Cable Clips



Intruder Alarm Cable

Unscreened LSZH 12 Core Type 1

- DECLARATION OF PERFORMANCE - No. CPR001/LSZH5**
- Unique identification code of the product-type:
BS 4737 Type 1 Unscreened Low Smoke Zero Halogen
 - Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):
VSZ-12W
 - Intended use or uses of the construction product, in accordance with the applicable harmonized technical specifications, as foreseen by the manufacturer:
Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
 - Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
**Ventcroft Ltd.
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire.
WA7 1QG, United Kingdom.
Tel.: +44 1928 581098, Fax.: +44 1928 581099, Email.: sales@ventcroft.co.uk**



Ventcroft Limited
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire
WA7 1QG, UK
Telephone: 01928 581098
Fax: 01928 581099
E-Mail: info@ventcroft.co.uk
Web: www.ventcroft.co.uk



Fire Performance Cable

- Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
N/A
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 3
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
The determination of the product type on the basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product, carried out by the notified testing laboratory No. 2661 (BASEC)

| Essential characteristics | Performance | Harmonized technical specification |
|---------------------------|------------------|------------------------------------|
| Reaction to fire | E ₁₂₀ | EN50575:2014 |
| Dangerous substances | None | |

- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.
- This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:

Ian Rotherham (Name) Technical Director (function)
Runcorn, United Kingdom 1st July 2017 (place and date of issue) (Signature)



Registered Office: Faraday Road, Astmoor Industrial Estate, Runcorn, Cheshire, WA7 1QG
Registered in England, Reg No. 2038810



Fire Cable Clips



Intruder Alarm Cable

Screened PVC Type 2

DECLARATION OF PERFORMANCE - No. CPR001/VSCS

- Unique identification code of the product type:
BS 4737 Type 2 Screened PVC
- Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):
VSC-4W, VSC-5BR, VSC-56W, VSC-56BR, VSC-58W, VSC-58BR, VSC-S12W & VSC-S12BR
- Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:
Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
**Ventcroft Ltd.
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire.
WA7 1QG, United Kingdom.
Tel.: +44 1928 581098, Fax.: +44 1928 581099, Email.: sales@ventcroft.co.uk**
- Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
N/A
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 3
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
The determination of the product type on the basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product, carried out by the notified testing laboratory No. 2661 (BASEC)
- Declared performance

| Essential characteristics | Performance | Harmonized technical specification |
|---------------------------|-------------|------------------------------------|
| Reaction to fire | $E_{fl,w}$ | EN50575:2014 |
| Dangerous substances | None | EN50575:2014 |
- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:
Ian Rotheram (name) **Technical Director** (function)
Runcorn, United Kingdom **1st July 2017** (place and date of issue) (Signature)



Registered Office: Faraday Road, Astmoor Industrial Estate, Runcorn, Cheshire, WA7 1QG
Registered in England, Reg No. 2048811



Web: www.ventcroft.co.uk

Unscreened PVC Type 2

DECLARATION OF PERFORMANCE - No. CPR001/VSCUS

- Unique identification code of the product type:
BS 4737 Type 2 Unscreened PVC
- Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):
VSC-4W, VSC-4BR, VSC-6W, VSC-6BR, VSC-8W, VSC-8BR, VSC-12W & VSC-12BR
- Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:
Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
**Ventcroft Ltd.
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire.
WA7 1QG, United Kingdom.
Tel.: +44 1928 581098, Fax.: +44 1928 581099, Email.: sales@ventcroft.co.uk**
- Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
N/A
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 3
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
The determination of the product type on the basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product, carried out by the notified testing laboratory No. 2661 (BASEC)
- Declared performance

| Essential characteristics | Performance | Harmonized technical specification |
|---------------------------|-------------|------------------------------------|
| Reaction to fire | $E_{fl,w}$ | EN50575:2014 |
| Dangerous substances | None | EN50575:2014 |
- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:
Ian Rotheram (name) **Technical Director** (function)
Runcorn, United Kingdom **1st July 2017** (place and date of issue) (Signature)



Registered Office: Faraday Road, Astmoor Industrial Estate, Runcorn, Cheshire, WA7 1QG
Registered in England, Reg No. 2048811



Web: www.ventcroft.co.uk

Unscreened PVC Type 3

DECLARATION OF PERFORMANCE - No. CPR001/VUCUS

- Unique identification code of the product type:
BS 4737 Type 3 Unscreened PVC
- Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):
VUC-4W, VUC-4BR, VUC-6W, VUC-6BR, VUC-8W, VUC-8BR, VUC-12W & VUC-12BR
- Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:
Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
- Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):
**Ventcroft Ltd.
Faraday Road
Astmoor Industrial Estate
Runcorn, Cheshire.
WA7 1QG, United Kingdom.
Tel.: +44 1928 581098, Fax.: +44 1928 581099, Email.: sales@ventcroft.co.uk**
- Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):
N/A
- System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:
System 3
- In case of the declaration of performance concerning a construction product covered by a harmonized standard:
The determination of the product type on the basis of type testing (based on sampling carried out by the manufacturer), type calculation, tabulated values or descriptive documentation of the product, carried out by the notified testing laboratory No. 2661 (BASEC)
- Declared performance

| Essential characteristics | Performance | Harmonized technical specification |
|---------------------------|-------------|------------------------------------|
| Reaction to fire | $E_{fl,w}$ | EN50575:2014 |
| Dangerous substances | None | EN50575:2014 |
- The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8.
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:
Ian Rotheram (name) **Technical Director** (function)
Runcorn, United Kingdom **1st July 2017** (place and date of issue) (Signature)



Registered Office: Faraday Road, Astmoor Industrial Estate, Runcorn, Cheshire, WA7 1QG
Registered in England, Reg No. 2048811



Web: www.ventcroft.co.uk