

Product Certification Schedule

Schedule No: 152/001/039

Licensee: VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE

Factory: VENTCROFT LIMITED, FARADAY ROAD, ASTMOOR INDUSTRIAL ESTATE, RUNCORN, CHESHIRE, WA7 1PE

Specification: BS 7629-1:2015 Electric Cables - Specification for 300/500 V fire resistant, screened, fixed installation cables having low emission of smoke and corrosive gases when affected by fire. Part 1: Multicore cables

Type of Cable: Table 2 Dimensions of 2-core, 3-core and 4-core cables

HAR Document: Not applicable

HAR Specification: Not applicable

Range of Approval: 1.0sqmm nominal cross-sectional area of conductor. 2-core.
1.5sqmm to 4.0sqmm nominal cross-sectional area of conductors inclusive.
2-core to 4-core inclusive.
STANDARD 60.
Additionally tested to BS 6387 Categories C, W & Z
Sheath - LTS3. Insulation - EI2.

Origin Thread: Not applicable

Origin Mark: NOBURN PLATINUM

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 07/12/2019

Signed for and on behalf of the British Approvals Service for Cables

Date 21/12/2016

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.

