

Certificate of Product Approval

Certificate Number: 682c

Issue: 10

VENTCROFT LIMITED

Faraday Road
Astmoor Industrial Estate
Runcorn
Cheshire
WA7 1PE
UNITED KINGDOM



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
NoBurn XP

Standard(s) (see Appendix for details)

BS 6387:2013 (Category CWZ)
EN 60754-1:2014
EN 61034-2:2005+A1:2013
EN 50200:2015 Annex E (30 mins)
EN 50200:2015 (Class PH120)
EN 60332-3-24:2009
EN 60332-3-25:2009

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd.

Karen Coull
Certification Scheme Manager

17 July 2019
Date of Issue

10 April 2013
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 682c VENTCROFT LIMITED

Issue: 10

Product name						LPCB Ref. No.
NoBurn XP						682c/01
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 6387	EN 60754-1	EN 61034-2	EN 50200 Annex E	EN 50200
1.0 ⁽¹⁾	2, 3 & 4	C, W, Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120
1.5 ⁽¹⁾	2, 3 & 4	C, W, Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120
2.5 ⁽¹⁾	2, 3 & 4	C, W, Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120
4.0 ⁽²⁾	2, 3 & 4	C, W, Z	<0.5% HCl	>60%	30min ⁽³⁾	Class PH120

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. Stranded conductor only.
3. The duration of 30 min when tested in accordance with EN 50200: 2015 Annex E is achieved by 15 min for the fire and mechanical shock phase and a further 15 min for the fire mechanical shock and water phase.
4. Where the cable diameter is greater than 12mm the cable is additionally approved to EN 60332-3-24.
5. Where the cable diameter is equal to or less than 12mm the cable is additionally approved to EN 60332-3-25.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd.

Karen Coull
Certification Scheme Manager

17 July 2019
Date of Issue

10 April 2013
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.

